

06 526

EXHIBIT A

SPECIFICATIONS

FERRIC CHLORIDE

2007

260 TONS
(100% FeCl₃)

Sewage Treatment Grade Ferric Chloride Solution. Not less than 30% or greater than 40% Ferric Chloride as determined by seasonal weather conditions. S.G. 1.4 at 25°/4° with 39% Ferric Chloride. Viscosity at 25° to be 6 centistokes.

The bid price should be per dry ton. This price must include the shipping costs. All shipping must be procured by the bidder.

Specified quantity is approximate only. The actual amount needed is dependent upon various plants phosphorus loadings and sludge handling requirements.

Delivery to be made F.O.B. within three (3) days of notification in bulk shipments of 4,000 gallons to Summit County Plant #25, 2910 North River Road, Stow or Summit County Plant #36, 1100 Loamshire Dr., Springfield Township.

Suppliers to adapt hoses to accommodate 2" male Evertight fitting.

Bidders must submit with the bid a specification sheet concerning the material bid, as well as a Material Safety Data Sheet.

Current contract runs through February 28, 2007. This contract will be effective no sooner than March 1, 2007 or as soon as possible after that date.

*Contract to remain in effect until February 29, 2008.